

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-L60314-212-01306791-3  
**Report Reference** E60314-19760310  
**Date** 28-Sep-2023

**Issued to:** Mersen USA Newburyport-Ma L L C  
374 MERRIMAC ST  
NEWBURYPORT, MA 01950-1930  
United States

**This is to certify that representative samples of** JFHR2 - Special-purpose Fuses - Component  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.

**Standard(s) for Safety:** UL 248-1, 4th Ed., Issue Date: 2022-10-24

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-L60314-212-01306791-3  
**Report Reference** E60314-19760310  
**Date** 28-Sep-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
A100P, Cat. Nos. A100P followed by 35 through 600, followed by 4 for Type 4, may be followed by TA or TI.	Fuses for protection of semi-conductor devices
A50P Series, Rated 500 v, ac, 450 v, dc	Fuses for protection of semi-conductor devices
A50P, A70P 20-30 amp Employ 100KA-AC-DC int rating.	Fuses for protection of semi-conductor devices
A50P, A70P, followed by suffix numbers 10 thru 800 and Type 1 or 4.	Fuses for protection of semi-conductor devices
A50P, may be followed by 4TA or 4TI for ratings 65 to 800 amp.	Fuses for protection of semi-conductor devices
A70P	Fuses for protection of semi-conductor devices
A70P, 700 v, 700 v, ac, 650 v, dc,	Fuses for protection of semi-conductor devices
A70P, may be followed by 4TA or 4TI for ratings 35-700A only.	Fuses for protection of semi-conductor devices
A70P800	Fuses for protection of semi-conductor devices
A70P8004TI	Fuses for protection of semi-conductor devices

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

