

AT 3636

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Low-Voltage Fuse-Switch-Disconnector

Mersen France SB SAS 15 Rue Jacques de Vaucanson, 69720 Saint Bonnet de Mure, France

Mersen France SB SAS 15 Rue Jacques de Vaucanson, 69720 Saint Bonnet de Mure, France

Mersen CZ s.r.o. Pardubická 437, 53304 Sezemice, Czech Republic

Additional Information on page 2

AC-21B: Ue = AC 690 V, le = 250 A; AC-22B: Ue = AC 690 V, le = 250 A; AC-23B: Ue = AC 500 V, le = 250 A; For use with fuse-links NH1/gG with power dissipation of max. 23 W. See also page 6 of test report.

MERSEN

MULTIVERT 250

Vertical fuse-switch-disconnector, 1pole or 3pole operated. Also found to be in conformity with IEC 60947-3:2008+AMD1:2012+AMD2:2015 used in conjunction with IEC 60947-1:2007+AMD1:2010+AMD2:2014.

☐ Additional Information on page 2

IEC 60947-1:2007 IEC 60947-3:2008

SGP-05833/Multivert/250/CB

This CB Test Certificate is issued by the National Certification Body

OVE

Date: 2016-12-22

AUSTRIAN ELECTROTECHNICAL ASSOCIATION

Kahlenberger Str. 2A 1190 Wien, Austria

ignature: Dipl.-Ing. W. Martin

Digitally signed by W. Martin Email=w.martin@ove.at

in A

ZVR: 327279890 | DVR: 1055887