



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010302649250

## NAME AND ADDRESS OF THE APPLICANT

Mersen France SB S.A.S.  
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

## NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB S.A.S.  
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

## NAME AND LOCATION OF THE FACTORY

Nolam Tunisia  
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis,Tunisie

## PRODUCT NAME,MODEL AND SPECIFICATION

Fuse Disconnecter

CMS22:Uimp: 8kV;Ui:690V;Ith:100A;Ue: AC500/690V;Ie:100A;Iq:100kA;Utilization Category:AC-20B;Poles: 1P、  
1P+N、 2P、 3P、 3P+N;Applicable frequency : 50/60Hz;IP20;Attached Auxiliary Contacts:1NC 或 2NC;Ith : 5A;AC-12 :  
220V/5A, DC-13 : 120V/0.2A;See the appendix

## STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Jun.27,2024

**Valid until:** Jun.26,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to  
the website of the issuing authority, or on the website of the CNCA ([www.cnca.gov.cn](http://www.cnca.gov.cn)).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010302649250

Appendix : Page 1 of 1

Type description:

CMS22 □ □ □

① ② ③ ④

①: Fuse diameter used 使用的熔体尺寸

②: Number of poles 极数 : 1P:1; 2P:2; 3P:3

③: N:Neutral;带中性极

Blank:without Neutral;不带中性极

④: I:Indicator ; 带指示灯

M: Microswitch; 带微动开关

MI: Microswitch and Indicator 带指示灯和微动开关

BLANK: without Microswitch and Indicator; 空白: 无指示灯和微动开关

P- means prepared, can be mounted later with Microswitch or Indicator.准备着, 以后可安装微动开关和指示灯

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.