



# 中国国家强制性产品认证证书

证书编号：2024010308649238

认证委托人名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产者名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产企业名称及地址

Nolam Tunisia

rue de Nabeul lot n° 4 zone industrielle de M' Ghira ,Tunis, Tunisie

产品名称和系列、型号、规格

半导体设备保护用熔断体

FD20GB100V□(T), FD20GC100V□(T) (型号解释详见附页); Un=DC1000V;

In: FD20GB100V□(T): 6A, 8A, 10A, 12A, 16A, 20A, 25A, 32A; FD20GC100V□(T): 40A, 50A, 63A; I1=50kA; 分断范围和使用类别: gR

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2024年06月27日 有效期至: 2029年06月26日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,  
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号：2024010308649238

证书附页：第 1 页 共 2 页

型号解释：

**FD20□100V□□**

**Example : FD20GB100V12T or FD20GC100V40T**

**FD:** means Protistor French ferrule for DC applications

**20:** means the diameter of the fuse for a length of 127 mm

**□: GB or GC:** curve type gR ( B or C, internal codification by Development, extend new range)

**100V:** means rated voltage 1000 volts

**□:** means the current nominal rating of fuse in amps

**□:** Blank or T means that the fuse has a striker

本页为证书附页，应与证书主页同时使用。



**中国质量认证中心**  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



# 中国国家强制性产品认证证书

证书编号：2024010308649238

证书附页：第 2 页 共 2 页

分断能力	型号	电流
1000V DC 50 kA	FD20GB100V6T	6
	FD20GB100V8T	8
	FD20GB100V10T	10
	FD20GB100V12T	12
	FD20GB100V16T	16
	FD20GB100V20T	20
	FD20GB100V25T	25
	FD20GB100V32T	32
	FD20GC100V40T	40
	FD20GC100V50T	50
	FD20GC100V63T	63
	FD20GB100V6	6
	FD20GB100V8	8
	FD20GB100V10	10
	FD20GB100V12	12
	FD20GB100V16	16
	FD20GB100V20	20
	FD20GB100V25	25
	FD20GB100V32	32
	FD20GC100V40	40
	FD20GC100V50	50
FD20GC100V63	63	

本页为证书附页，应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010308649238

## **NAME AND ADDRESS OF THE APPLICANT**

Mersen France SB S.A.S.  
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

## **NAME AND ADDRESS OF THE MANUFACTURER**

Mersen France SB S.A.S.  
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

## **NAME AND LOCATION OF THE FACTORY**

Nolam Tunisia  
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis,Tunisie

## **PRODUCT NAME,MODEL AND SPECIFICATION**

Fuse-links for the protection of semiconductor devices  
FD20GB100V□(T),FD20GC100V□(T);Un=DC1000V;  
In:FD20GB100V□(T):6A,8A,10A,12A,16A,20A,25A,32A;FD20GC100V□(T):40A,50A,63A;I1=50kA  
;Breaking Range and Utilization Category:gR

## **STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Jun.27,2024

**Valid until:** Jun.26,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010308649238

Appendix : Page 1 of 2

Type description:

**FD20□100V□□**

**Example : FD20GB100V12T or FD20GC100V40T**

**FD:** means Protistor French ferrule for DC applications

**20:** means the diameter of the fuse for a length of 127 mm

**□: GB or GC:** curve type gR ( B or C, internal codification by Development, extend new range)

**100V:** means rated voltage 1000 volts

**□:** means the current nominal rating of fuse in amps

**□:** Blank or T means that the fuse has a striker

This page is attached to the certificate and should be used at the same time as the certificate page.



**中国质量认证中心**  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010308649238

Appendix : Page 2 of 2

分断能力	型号	电流
1000V DC 50 kA	FD20GB100V6T	6
	FD20GB100V8T	8
	FD20GB100V10T	10
	FD20GB100V12T	12
	FD20GB100V16T	16
	FD20GB100V20T	20
	FD20GB100V25T	25
	FD20GB100V32T	32
	FD20GC100V40T	40
	FD20GC100V50T	50
	FD20GC100V63T	63
	FD20GB100V6	6
	FD20GB100V8	8
	FD20GB100V10	10
	FD20GB100V12	12
	FD20GB100V16	16
	FD20GB100V20	20
	FD20GB100V25	25
	FD20GB100V32	32
	FD20GC100V40	40
FD20GC100V50	50	
FD20GC100V63	63	

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.