



中国国家强制性产品认证证书

证书编号：2024010308649247

认证委托人名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产者名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产企业名称及地址

Nolam Tunisia

rue de Nabeul lot n° 4 zone industrielle de M' Ghira ,Tunis,Tunisie

产品名称和系列、型号、规格

半导体设备保护用熔断体

SC31AR (型号解释详见附页);

Un:AC690V; In:315A, 350A, 400A, 450A, 500A; I1:100kA; 分断范围和使用类别:aR

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024年06月27日 有效期至：2029年06月26日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010308649247

证书附页：第 1 页 共 1 页

型号解释：

SC 31 AR □ □ □ □

- 特殊后缀/Special suffix
- 端子/Termination
- 电流/Rating
- 电压除以 10/Voltage (V/10)
- 曲线类型/Type of curve
- 陶瓷管尺寸/Size of body
- 技术类型/technology type

SC	31	AR	69V	500	TF	U or blank
技术类型 technology type	陶瓷管尺寸 Size of body	曲线类型 Type of curve Class aR	电压/10 Voltage/10	电流 Rating	端子 Termination TF-End contacts (公制螺纹) TI- End contacts (英制螺纹)	特殊后缀 Special suffix U-without indicator U-不带指示器 M-with microswitch M-带微动开关 Blank- with indicator 空白-带指示器

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010308649247

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND LOCATION OF THE FACTORY

Nolam Tunisia
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis,Tunisie

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse-link for the protection of semiconductor devices
SC31AR; Un:AC690V;In:315A,350A,400A,450A,500A;I1:100kA;Breaking Range and Utilization
Category:aR

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.27,2024

Valid until: Jun.26,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，不得单独使用
This translated document does not have legal validity and cannot be used in isolation

CERTIFICATE NO. : 2024010308649247

Appendix : Page 1 of 1

Type description :

SC 31 AR □ □ □ □

SC	31	AR	69V	500	TF	U or blank
技术类型 technology type	陶瓷管尺寸 Size of body	曲线类型 Type of curve Class aR	电压/10 Voltage/10	电流 Rating	端子 Termination TF-End contacts (公制螺纹) TI- End contacts (英制螺纹)	特殊后缀 Special suffix U-without indicator U-不带指示器 M-with microswitch M-带微动开关 Blank- with indicator 空白-带指示器

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.