



中国国家强制性产品认证证书

证书编号：2017010308021088

委托人名称、地址

Mersen France SB SAS

15 Rue Vaucanson, F69720 Saint Bonnet de Mure, France

生产者（制造商）名称、地址

Mersen France SB SAS

15 Rue Vaucanson, F69720 Saint Bonnet de Mure, France

生产企业名称、地址

Nolam Tunisia

rue de Nabeul lot n° 4 zone industrielle de M' Ghira , Tunis, Tunisie

产品名称和系列、规格、型号

半导体设备保护用熔断体

FD20GB150V□(T),FD20GD150V□(型号解释详见附件);Un=DC1500V;

In:FD20GB150V□(T):0.8A,1A,1.5A,2A,3.15A,4A,5A;

FD20GD150V□:6A,8A,10A,12A,16A,20A,25A;I1=30kA;分断范围和使用类别:gR

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2017年12月27日 有效期至：2022年12月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010308021088

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB SAS
15 Rue Vaucanson, F69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB SAS
15 Rue Vaucanson, F69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE FACTORY

Nolam Tunisia
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis, Tunisie

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-links for the protection of semiconductor devices
FD20GB150V□(T), FD20GD150V□; U_n=DC1500V; I_n: FD20GB150V□(T): 0.8A, 1A, 1.5A, 2A, 3.15A, 4A, 5A; FD20GD150V□: 6A, 8A, 10A, 12A, 16A, 20A, 25A; I₁=30kA; Breaking Range and Utilization Category: gR

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Dec.27,2017

Valid until: Dec.27,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2017010308021088

纸 号: 1724843

型号解释:

FD20□150V□□

Example : FD20GB150V5T or FD20GD150V25

FD: means Protistor French ferrule for DC applications

20: means the diameter of the fuse for a length of 127 mm

□: GB or GD: curve type gR (B or D, internal codification by Development, extend new range)

150V: means rated voltage 1500 volts

□: means the current nominal rating of fuse in amps

□: Blank or T means that the fuse has a striker

注: 此附录与证书同时使用时有效。



主 任 :



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号：2017010308021088

纸 号：1724843

1500V DC 30kA	FD20GB150V0.8	0.8
	FD20GB150V1	1
	FD20GB150V1.5	1.5
	FD20GB150V2	2
	FD20GB150V3.15	3.15
	FD20GB150V4	4
	FD20GB150V5	5
	FD20GD150V6	6
	FD20GD150V8	8
	FD20GD150V10	10
	FD20GD150V12	12
	FD20GD150V16	16
	FD20GD150V20	20
	FD20GD150V25	25
	FD20GB150V0.8T	0.8
	FD20GB150V1T	1
	FD20GB150V1.5T	1.5
	FD20GB150V2T	2
	FD20GB150V3.15T	3.15
	FD20GB150V4T	4
FD20GB150V5T	5	

注：此附录与证书同时使用时有效。



主 任：



中国质量认证中心