



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016010308931524

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB SAS
15 Rue Jacques Vaucanson, 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB SAS
15 Rue Jacques Vaucanson, 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE FACTORY

Nolam Tunisie
rue de Nabeul lot n° 4 zone industrielle de M' Ghira ,Tunis,Tunisie

NAME, MODEL AND SPECIFICATION

SEMICONDUCTOR PROTECTION FUSES

FR14GR; Un: AC690V; In:
1A, 2A, 4A, 6A, 8A, 10A, 12A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Rated breaking
capacity(I1): 160kA; Breaking Range and Utilization Category: gR ;See the
Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jan. 20, 2017 Date of expiry: Dec. 27, 2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec. 27, 2016

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1601962



中国国家强制性产品认证证书

证书编号: 2016010308931524

委托人名称、地址

Mersen France SB SAS
15 Rue Jacques Vaucanson, 69720 Saint Bonnet de Mure, France

生产者(制造商)名称、地址

Mersen France SB SAS
15 Rue Jacques Vaucanson, 69720 Saint Bonnet de Mure, France

生产企业名称、地址

Nolam Tunisie
rue de Nabeul lot n° 4 zone industrielle de M' Ghira ,Tunis, Tunisie

产品名称和系列、规格、型号

半导体设备保护用熔断体

FR14GR; Un: AC690V; In:
1A, 2A, 4A, 6A, 8A, 10A, 12A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; 额定分断能力I1:
160kA; 分断范围和使用类别: gR; 型号解释详见附件

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2017年01月20日 有效期至: 2021年12月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年12月27日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1601962



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2016010308931524

纸号: 1601962

型号解释:

<u>FR</u>	<u>14</u>	<u>GR</u>	<u>69V</u>	<u>□</u>	<u>□</u>
1	2	3	4	5	6

- 1: FR : basic model, means French ferrule
- 2: 14 : for diameter of fuses 14x51
- 3: GR : fuse curve
- 4: 69V: rated voltage 690V
- 5: rated current in amps
- 6 (optional) : T for striker

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



