



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

Certificate No.: CE190315006350-A1

**Product** Fuse-holder

**Applicant** MERSEN USA NEWBURYPORT-MALLC  
374 MERRIMAC ST NEWBURYPORT MA 01950, USA

**Type/Model** US6J\*

**Technical data** Un: AC600V,DC600V; In:60A;  
I1:100kA(600VAC),50kA(,600VDC); 1P,2P,3P; IP20

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2018CQC0315-009807-1-A1,00901-CE2018CQC0315-009807-2-A1, the submitted sample(s) of the above item complies with:

**EN 60269-1:2007+A1:2009;HD 60269-2:2013**

and fulfills testing requirements of the European Directive:

**Low Voltage Directive (LVD):2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from:** Jun.18,2021

**Valid until:** Jun.18,2024

President:

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0011522