



Certificate of Compliance

Certificate: 70195773 **Master Contract:** 162842 (032169_0_000)
Project: 70195773 **Date Issued:** 2018-11-28
Issued to: Mersen USA Newburyport-MA, LLC
374 Merrimac St
Newburyport, Massachusetts 01950-1998
USA
Attention: Marla Miller

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ramana Tangirala*
Ramana Tangirala

PRODUCTS

CLASS - C622501 - FUSEHOLDER ASSEMBLIES

Fuseholders, **Cat No. CUSCC** followed with suffixes, Dead Front Fuseholder Class CC, 1 to 4 pole, 30A max, 600V ac max, 600V dc max, SC Withstand rating - 200kA at 600V ac and 100kA at 600V dc, intended for DIN rail mounting, Provided with or without Blown Fuse Indicator.

APPLICABLE REQUIREMENTS

CSA standard C22.2 No. 4248.1 - Fuseholders – Part 1: General Requirements
CSA standard C22.2 No. 4248.4 - Fuseholders – Part 4: Class CC



Supplement to Certificate of Compliance

Certificate: 70195773

Master Contract: 162842 (032169_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70195773	2018-11-28	Covers original certification of Fuseholders, Cat No. CUSCC followed with suffixes, Dead Front Fuseholder Class CC, 1 to 4 pole, 30A max, 600V ac max, 600V dc max.