

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	Mersen France SB SAS			
Address	15, Rue Jacques de Vaucanson, Saint Bonnet De Mure, 69720, France			
Type	Switches - Ac			
Description	Fuse switch-disconnector			
	TYPE	LINOCUR D02	05861.063040 - 1 pole 05862.063040 - 2 poles 05863.063040 - 3 poles 05863.063140 - 3 poles + neutral	
Trade Name	LINOCUR D02			
Application	Marine application for use in environmental categories ENV1 and ENV2 as defined in LR Type Approval System, Test Specification Number 1-2002.			
Specified Standard	IEC 60947-3: 2015.07 Ed 3.2 DIN VDE 0638: 09.81 + A1: 2005.09			
Ratings	Utilization Category	Rated Voltage Ue	Rated Current Ie	Thermal Current Ith
	AC 22 B	255/ 440	2 - 63	63
	AC 23 B	255/ 440	2 - 35	35

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Type Approval Certificate

AC 23 B	255/ 400	2 - 50	50
DC 22 A	65	2 - 63	63
AC 22	230/ 400	2 - 63	63

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. HTS/ETS 40521-20/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.