



Lloyd's
Register


Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER	Mersen France SB S.A.S. 15, Rue de Vaucanson 69720 Saint Bonnet de Mure FRANCE
PLACE OF PRODUCTION	Nolam Tunisia Rue de Nabeul lot no. 4 zone industrielle de M'Ghira TUNISIA
DESCRIPTION	Fuse holders, 690 V, with or without accessories
TYPE	CMS 14 – 690 V : 50 A max CMS 22 – 690 V : 125 A max
APPLICATION	Industrial application for Switch- and Control gear
STANDARDS:	IEC 60269-1; 2006 60269-2-1; 2006 60269-2; 2006 60947-1; 2007 60947-3; 2008

Certificate No.	19/30005
Issue Date	9 July 2019
Expiry Date	16 March 2024
Sheet	1 of 2



Lloyd's Register EMEA

Lloyd's Register EMEA, Rotterdam Technology Support Office, K.P.v.d.Mandelelaan 41a, 3062 MB Rotterdam, The Netherlands

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Lloyd's
Register

RATINGS

	CMS 14	CMS 22
Voltage:	690 V	690 V
Fuse:	50 A max	125 A max
Poles:	1 to 4 and N, 1 + N and 3 + N poles	1 to 4 and N, 1 + N and 3 + N poles

ACCESSORIES: Fuse holders CMS 14 and CMS 22,

DEGREE OF PROTECTION: IP 20

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. PRJ1109988934 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 03/30002 to which this extension should be attached.

Certificate No.	19/30005
Issue Date	9 July 2019
Expiry Date	16 March 2024
Sheet	2 of 2

G.J.Vromans

Lloyd's Register EMEA

Lloyd's Register EMEA, Rotterdam Technology Support Office, K.P.v.d.Mandelelaan 41a, 3062 MB Rotterdam, The Netherlands

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.